



# Sierra Safety Technology Corporation

## Application Note - Mounting Screws

Custodian:	<b>Sales</b>	Part Name:	<b>RED1 All Versions</b>	
Date:	<b>October 31, 2000</b>	Part No.:	<b>Tube Seal</b>	
Status:	<b>Final</b>	Revision:	<b>1.0</b>	
<b>Revision and ECO Incorporation Record</b>				
Rev.	Date	ECO No.	By	Description

This application note applies to all RED1 Detectors.

The RED1 uses two UV Sensor Tubes mounted to the top PC board under the faceplate. One of the UV Sensor Tubes is mounted in a way that places the pointed end near to one of the mounting screws.

Caution must be exercised when removing and replacing this screw to insure that the screwdriver blade does not break the tip of the UV Sensor Tube. When removing or replacing visually insure that the blade of the screwdriver when rotated does not come in contact with the UV Sensor Tube Tip. Using a smaller screwdriver or moving the screwdriver away from the tip when turning the screwdriver will prevent the UV Sensor Tube Tip from being broken. See Illustration below for location of parts.

